


LOWER LEVEL FLOOR PLAN
SCALE: 1/8" = 1'-0"

- DEMOLITION GENERAL NOTES THIS SHEET:
1. REMOVE ALL FIRE ALARM DEVICES AND WIRING.
 2. RETAIN ACCESS CONTROL WIRING FROM REMOVED DEVICES AND USE AS EXISTING DEVICES.
- DEMOLITION NOTES THIS SHEET:
- 1. REMOVE ACCESS CONTROL PANEL FROM ABOVE CEILING. SECURE CABLING ABOVE CEILING FOR ACCESS CONTROL. MONITORING AND SIGNALING DEVICES FROM DOORS AT GATES 2 AND 3.
 - 2. REMOVE ACCESS CONTROL PANEL FROM ABOVE CEILING. SECURE CABLING ABOVE CEILING FOR ACCESS CONTROL. MONITORING AND SIGNALING DEVICES FROM DOORS AT GATES 4 AND 5.
 - 3. REMOVE ACCESS CONTROL PANEL FROM ABOVE CEILING. SECURE CABLING ABOVE CEILING FOR ACCESS CONTROL. MONITORING AND SIGNALING DEVICES FROM DOOR AT DM-1.
 - 4. REMOVE CARD READER, LOCAL AUDIO ALARM INSIDE AND OUTSIDE, AND REMOVE PUSH-BUTTON REQUEST TO ENTER. RETAIN WIRING FOR PULL STRING TO INSTALL ACCESS CONTROLLER.
 - 5. REMOVE KEYPAD AND PATCH-HOLE TO MATCH SURROUNDING FINISHES.
 - 6. REMOVE LOCAL AUDIO ALARM FOR ACCESS CONTROLLER ON UPPER FLOOR FOR DOOR ABOVE.



THESE DRAWINGS ARE BASED ON HISTORICAL DRAWINGS OF THE EXISTING BUILDING. CONTRACTOR SHALL VERIFY ALL CONDITIONS PRIOR TO FABRICATION OF SYSTEM. MODIFICATIONS SHALL BE MADE ONLY AFTER APPROVAL BY THE ENGINEER.



HURD & OBENCHAIN, INC.
CONSULTING ENGINEERS

4932 FRONTAGE ROAD NW, ROANOKE, VIRGINIA 24019
540/285-4444

11508 ALLENCING PARKWAY, RICHMOND, VIRGINIA 23235
804/423-6444

A C E C

FIRE ALARM & CARD READER SECURITY SYSTEMS IMPROVEMENT FOR LYNCHBURG REGIONAL AIRPORT LYNCHBURG, VIRGINIA

ELECTRICAL - LOWER LEVEL		FLOOR PLAN - DEMOLITION	
DESIGNED	RJS	DRAWN	AB
CHECKED	RL	DATE	06/29/10
COMMISSION NUMBER	10180	SHEET NO.	E1.1