

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

Addendum for Invitation for Bids
Lynchburg Regional Airport New Air Traffic Control Tower
2016-0018

Date: 09/28/2015
From: Lisa Moss, Buyer VCA
RE: Addendum No. 4

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. Sheet C312 Detail 4 Swing Gate, Note 3 refers to Item F-162-5.4. This item is not on the bid form.
Revise Note 3 on Detail 4, Sheet C312 from "Item F-162-5.4" to "Item F-162-5.2a"

2. Specification Section L-128 Fiber Optic Cable - lists four (4) unit cost items not reflected on the bid form. L-128-5.1, L-128-5.2, L-128-5.3, L-128-5. Are these included in the 012100-2 Verizon Utility Allowance?
Specification Revision: Remove and replace Fiber Optic Cable specification sheet L-128-3. There are no L-128 pay items. Page 3 of revised specification attached.

3. Please review 087100.1.7.B Warranties. How are we to provide a lifetime warranty on these items? Please clarify and/or redefine warranty period.
Revise Door Hardware Specification Section 087100, Part 1, 1.7B to: "Power supplies and power controllers shall be warranted for 10 years from the date of occupancy. "

Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____ Fax No.: _____

Each event shall be tabulated on the OTDR with the following information:

- a. Event No.
- b. Location along the fiber (meters)
- c. Loss (dB)
- d. Attenuation up to the Event (dB/km)
- e. Reflection (dB)

Copies of OTDR reports shall be submitted to the Engineer.

These specifications do not allow for the acceptance of new optical fiber cables with any bad fibers. If any fibers of a particular cable do not meet the above performance specifications, the entire cable shall be removed and replaced at the contractor's expense – splices are not acceptable.

METHOD OF MEASUREMENT

128-4.1 Fiber optic cable shall not be measured for payment. Fiber optic cable shall be included in the allowance pay items.

BASIS OF PAYMENT

128-5.1 No separate payment shall be made for fiber optic cable.

END OF ITEM L-128

THIS PAGE INTENTIONALLY LEFT BLANK