

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids
Arkansas-Nevada Ave Water Line Replacement Plan**

13-849

Date: 6/19/13
From: Lisa Moss, Buyer VCA
RE: Addendum No. 2

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. In the Instructions for Bidders 7.4; It says lump sum but the bid form is set up for unit prices. Will this be a lump sum or unit priced project?

Project cost will be unit price based.

2. Just double checking, no traffic control plan is needed per Addendum #1, even though it states on the plan one is needed?

Because there is no through traffic, the Contractor will not be responsible for developing a traffic control plan with detour or flashboard signage. A simple sketch will suffice stating that traffic control will maintain private, commercial (mail, delivery) and emergency service access to all properties and will meet work zone protection requirements.

3. Since there is no soils report and this does say excavation is unclassified, is there any thought as to changing how rock is handled? There is always the possibility of the contractor beating on rock for 10 of the projects 90 calendar days and not getting much pipe in the ground. Could there be a line item for rock which would be there to cover any rock, even if none was hit? If this is a unit price project and none is hit then \$0 gets paid out. Otherwise, the prices the city will get from the contractors will include extra in the cost of pipe to cover any rock the contractors think they might hit, thus raising the price the city will pay per foot of pipe installed.

Excavation will be unclassified. Due to shallow nature of water line excavation and no stream or low points being crossed, we believe the risk of rock is minimal. Cost for rock removal will be at contractor's expense. If rock is encountered, the City will consider extra time based on a contractor's claim.

Company Name: _____ *Address:* _____ *Date:* _____

Authorized Signature: _____ *Title:* _____

Print Name: _____ *Telephone No.:* _____

Fax No.: _____