

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids
College Hill WTP Interior Renovations
2016-075**

Date: 05/19/2016
From: Lisa Moss, Buyer VCA
RE: Addendum No. 2

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. I need some direction on location of louver blinds for the above project. The specs note to see location on drawings, but I'm not seeing anything. Can you provide locations of louver blinds? (Div. 12 – Section 122113)

Answer: Louver blinds shall be provided at all windows in Training Room 208.

2. Are the new SSM window stools only located in the Men's Toilet #202? Or should the Men's Locker Room #201 & 203 also be included.

Answer: SSM window stools shall be provided in Men's Toilet 202, Men's Locker Room 202 and Men's New Locker Room 203.

3. Page 3 appears to missing from the tile section 093000 of the project manual. Can we receive page #3?

Answer: See attached missing page 3.

4. There is a note on page A1.4, elevation 3, it states *if the floor slopes cut base to make level – see detail 11/A1.4*. Ceramic tile base cannot be cut according to the contractor. They recommend leveling near the wall if necessary. Please advise and clarify.

Answer: The recommendation of leveling near the wall is accepted.

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____ Fax No.: _____

- B. Mortar Bond Coat Materials:
 - 1. Latex-Portland Cement type: ANSI A118.4.

2.04 GROUT MATERIALS

- A. Manufacturers:
 - 1. Bonsal American, Inc: www.sakrete.com
 - 2. Bostik Inc: www.bostik-us.com.
 - 3. Custom Building Products: www.custombuildingproducts.com.
 - 4. LATICRETE International, Inc: www.laticrete.com.
 - 5. Custom Building Products: www.custombuildingproducts.com.
 - 6. Substitutions: See Section 016000 - Product Requirements.
- B. Standard Grout: Any type specified in ANSI A118.6 or A118.7.
 - 1. Colors: To be selected by Architect from manufacturer's standard range.

2.05 ACCESSORY MATERIALS

- A. Backer board adhesive: Liquid Nails or equal.
- B. Cement-Based Tile Backer Board: Non-gypsum-based, cementitious board complying with ASTM C1288.
 - 1. Thickness: 1/4 inch.
 - 2. Products:
 - a. James Hardie Building Products, Inc; Hardibacker Cement Board.
 - b. CertainTeed; Fiber Cement BackerBoard.
- C. Mesh Tape: 2-inch wide self-adhesive fiberglass mesh tape.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that sub-floor surfaces are smooth and flat within the tolerances specified for that type of work and are ready to receive tile.
- B. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive tile.

3.02 PREPARATION

- A. Protect surrounding work from damage.
- B. Vacuum clean surfaces and damp clean.
- C. Seal substrate surface cracks with filler. Level existing substrate surfaces to acceptable flatness tolerances.
- D. Install cementitious backer board in accordance with ANSI A108.11 and board manufacturer's instructions. Tape joints and corners, cover with skim coat of dry-set mortar to a feather edge.
- E. Install tile backer board in strict accordance with manufacturer's instructions, using corrosion-resistant bugle head drywall screws or adhesive. Bed fiberglass self-adhesive tape at all joints and corners with material used to set tiles.
- F. Tile backer board adhesive attachment to masonry: Install board direct to masonry with adhesive. Beads of adhesive shall be 3/8 inch continuous and 8 inch on center. Clean masonry before application of adhesive for proper bonding.
- G. Prepare substrate surfaces for adhesive installation in accordance with adhesive manufacturer's instructions.

3.03 INSTALLATION - GENERAL

- A. Install tile and thresholds and grout in accordance with applicable requirements of ANSI A108.1 through A108.13, manufacturer's instructions, and The Tile Council of North America Handbook recommendations.
- B. Cut and fit tile to penetrations through tile, leaving sealant joint space. Form corners and bases neatly. Align floor joints.