

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids
Criminal Justice Academy Boiler Replacement**

13-844

Date: 6/12/2013
From: Lisa Moss, Buyer VCA
RE: Addendum No. 1

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. After the copper tees are installed in the 2 ½” HW line, can the 2” HW lines to the boilers be steel pipe ASTM A53 threaded?
Yes, it is acceptable for the 2” HW lines to the boilers to be steel pipe ASTM A53 threaded. The spec calls for welded, but threaded is also acceptable. As a note, please be aware of the required use of dielectric connections for joining dissimilar metals.
2. Is factory start up required on the boilers?
Yes
3. Can Armstrong pumps be substituted for the B & G?
Yes

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____

Fax No.: _____