

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids
E. C. Glass Tennis Court Reconstruction**

14-908

Date: 5/2/2014
From: Lisa Moss, Buyer VCA
RE: Addendum No. 2

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. **The colors of the Tennis Courts are to be Royal Blue and U.S. Open Green. Colors are to be from the Laykold Color Palette.**
2. **Access to tennis courts are to be from Langhorne Road side of building.**
3. **The start date of the project is to be June 23, 2014 and completion date to be no later than 80 days from the start date.**
4. Will the school be responsible for removing the wind screens?
Yes and LCS will mark size re-locations on fence.
5. Where are the contractors to dump the debris?
LCS will mark 2 locations on property for two truckloads to be dumped. At this time all other debris is to be removed.
6. How do you want contractors to handle areas where the old light pole bases are located?
Excavate 18" below grade to allow a minimum of 3" of compacted base over area.
7. Since we are essentially just replacing 3" of asphalt paving, could we not just mill off 3" of asphalt, laser grade the stone base and repave, instead of going deeper, removing some material and then adding 1" of fresh stone? There would be some significant cost savings to this approach.
As per scope; grade blended base materials to a grade of between 0.83% and 1.0%. Compact blended materials with 10-ton vibratory roller to a density of 95% Standard Compaction (ASTM D698). Contractor is to meet the requirements of the scope. If the contractor is able to do so using either blended or by adding new stone that will be acceptable. It is the responsibility of the contractor to accommodate proposed pavement and stone depths. The finished elevation of the new courts shall be the same as existing. (tie into existing curb)

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____

Fax No.: _____