

City of Lynchburg  
Procurement Division  
900 Church Street  
Lynchburg, Virginia 24504  
Telephone No.: (434) 455-3970  
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids  
IT BUILDING HVAC  
2016-058**

Date: 04/19/2016  
From: Lisa Moss, Buyer VCA  
RE: Addendum No. 2

---

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

- 1. Revision to Drawing MO.1: Mechanical Specifications, paragraph 2.04 Piping Schedule, Note to Include: Contractor may route new refrigerant piping to indoor units outside the building to the point where it can enter the building and not have to disturb walls and finishes to route new piping within the exterior walls. Existing piping within exterior walls may be abandoned in place.**
- 2. Revision to Drawing MO.1: Mechanical Specifications, paragraph 2.05 Insulation Schedule, Note #2 to Include: Apply two coats of Armaflex finish on all piping insulation exposed outdoors.**
- 3. The Bid submission date has been extended until 3:00 P.M. April 27, 2016.**

Company Name: \_\_\_\_\_ Address: \_\_\_\_\_ Date: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_ Title: \_\_\_\_\_

Print Name: \_\_\_\_\_ Telephone No.: \_\_\_\_\_ Fax No.: \_\_\_\_\_