

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids
Lynchburg Juvenile Services Group Home
2015-964**

Date: 3/5/2015
From: Lisa Moss, Buyer VCA
RE: Addendum No. 4

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

Addendum as prepared by Virginia A & E.

Contractors are invited to visit the site on Monday, March 9th, 2015 from 1 to 2 PM.

I – ADDITIONAL QUESTIONS SUBMITTED TO THE CITY OF LYNCHBURG:

1. Question: My name is Haynie Hite with WG Lesemann & Associates. My company represents Sloan Valve and Bradley Safecare products in the state of Virginia. I would like permission to quote my products for the above project.

Response: Specified products are the Basis-of-Design. Equal products will be considered during submittals.

2. Question: Refer to fixture P-1: The flush valve specified is as a standard concealed flush valve that includes a non ADA push button. Is this acceptable?

Response: Flush valve specification has been modified below.

3. Question: Refer to fixture P-1: The flush valve specified has a flush connection designed for wall mounted china. Considering the bowl specified is floor mounted / back inlet, the flushing tube will need to extend 2 5/8" minimum from finish wall to bowl inlet. This extension may offer a ligature point that was not anticipated. Is this acceptable?

Response: Flush valve specification has been modified below.

4. Question: Is Cell-TeK LSG Series Load Support Grid an acceptable substitution for the grass paver system?

Response: Cell-TeK LSG is an acceptable alternate to the Grass Paver system provided it meets or exceeds the weight requirements of the local fire department which is 75,000 lbs. Vendor will be required to confirm such as part of the submittal process.

II – ADDITIONAL CHANGES TO THE CONTRACT DOCUMENTS

1. Replace P-1 water closet on plumbing fixture schedule with the following: Vandal and ligature resistant, ADA, 1.6 GPF, floor mounted with top supply and rear outlet, exposed hydraulic flush valve cover with hydraulic flush valve Basis of design (or equal): Whitehall WH2142-ADA-T-2 and WH2802SLPT-ADA-EG10-1.6 Maximum 24" distance from front edge of water closet to pushbutton.

2. Specification Section 044313.13, Stone Masonry.
 - a. Revise paragraph 1.1.B to read as follows:
 - B. Masonry Veneer Manufacturer's Association.
 - b. Replace paragraph 2.1 to read as follows:
 - 2.1 Fasteners
 - A. Install manufacturer recommended lath fasteners every 6 inches vertically along metal stud.
 - c. Revise paragraph 2.3.B to read as follows:
 - B. Sizes: 5" – 24" lengths x nominal 2" depth.
 - d. Revise paragraph 2.4.C to read as follows:
 - C. Cut stones to produce pieces of thickness, size and shape indicated or required within fabrication tolerances recommended by the Masonry Veneer Manufacturer's Association.
 - e. Add paragraphs 3.1.G and H as follows:
 - G. If installing over rigid insulation board, consult with a registered engineer to determine if any additional fastener requirements are needed to support the weight of the veneer system.
 - H. Installation shall be in strict accordance with the manufacturer's instructions and local building code requirements.
3. Drawing A312 – Wall Section/Details
 - a. Change Detail 1 WALL BASE SECTION per attachment ASD 9.
 - b. Change Detail 5 PUNCHED WINDOW DETAIL per attachment ASD 10.
4. Drawing A313 – Section Details
 - a. Change Detail 7 ROOF DETAIL per attachment ASD 11.
5. Drawing A610 – Window Frame Types & Elevations
 - c. Change window type H5 to be 4'-8" in length.

ATTACHMENTS

1. ASD 9. DRAWING 1/A312 WALL BASE SECTION (1 page)
2. ASD 10. DRAWING 5/A312 PUNCHED WINDOW DETAIL (1 page)
3. ASD 11. DRAWING 7/A313 ROOF DETAIL (1 page)

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____

Fax No.: _____