

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

Addendum for Invitation for Bids
Lynchburg Police Department Interview Room Renovations
2016-028

Date: 11/06/2015
From: Lisa Moss, Buyer VCA
RE: Addendum No. 2

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. Does the wall insulation go above the 7'6" finished ceiling height.
Wall insulation goes from top of wall to bottom of structure as indicated on Drawing A2 Wall Types.

2. Is there any insulation in the ceiling, if so do you want it on the drop ceiling or fasten to the existing ceiling or floor joist above.
No insulation in the ceiling.

3. Can you give us more detail for the sound attenuation batt insulation.
Provide unfaced glass fiber acoustical insulation complying with ASTM C 665, Type I. Surface burning characteristics of maximum flame spread of 10. Maximum smoke developed of 10 when tested in accordance with ASTM 84. Combustion characteristics shall comply with ASTM E 136.

4. Can we use a grid system similar to a drop ceiling instead of the 1 1/2 " metal studs in Note 7 on A2?
Any manufactured ceiling system designed to support a 5/8" GWB ceiling is acceptable.

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____ Fax No.: _____