

City of Lynchburg  
Procurement Division  
900 Church Street  
Lynchburg, Virginia 24504  
Telephone No.: (434) 455-3970  
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids  
P.L. Dunbar M.S. Boiler Replacement and Heating System Alteration**

**15-941**

Date: 10/23/2014  
From: Lisa Moss, Buyer VCA  
RE: Addendum No. 2

---

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. "One cast iron steam boiler specifications say Burnham model V-1117H 3425MBH output or equal. We would like to quote a Weil-McLain model BG-1388-SF see attached brochure. There would not be any additional work required to install this boiler. What is the procedure to have other manufacturers products considered as equals for this project?"

**Per Specification section 230100, paragraph 2.5.C.: Submit a request for substitution for any manufacturer and model not stipulated. The Owner approval or disapproval of proposed substitutions shall be addressed by Addendum prior to receipt of bids.**

**After review of the product information received, the Weil-McLain BG-1388-SF is approved as an alternative to the specified boiler and may be considered by the bidding Contractors.**

2. "Two condensing hot water boilers specification says Patterson Kelley model C-1050. We would like to quote Two Weil-McLain model SF1000 see attached brochure. There would not be any additional work required to install these boilers."

**After review of the product information received, the Weil-McLain SF1000 is not approved as an alternative to the specified boiler due to the capacity and physical size**

Company Name: \_\_\_\_\_ Address: \_\_\_\_\_ Date: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_ Title: \_\_\_\_\_

Print Name: \_\_\_\_\_ Telephone No.: \_\_\_\_\_

Fax No.: \_\_\_\_\_