

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids
Public Safety Building RTU Replacement**

2015-967

Date: 04/08/2015
From: Lisa Moss, Buyer VCA
RE: Addendum No. 2

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. Concerning drawing ME2: Electrical Specifications, Fire Alarm Systems Notes A, B and C. Who maintains the existing Fire Alarm System? Who is the manufacturer of the existing fire alarm system?

There is no existing fire alarm system in this building.

2. PAHU-1 and PAHU-2 as currently drawn are based on having preheat coils which are deleted under Addendum No. 1. They do not include controls cabinets which will be required for the basis-of-design units. Include the following requirements for each unit:

PAHU-1: Basis-of-design make/model shall include a single controls module which shall contain the VFD and unit controller, factory mounted and wired. The net effect of deleting the preheat coil and adding the controls module is an increase in length of the unit of approximately 6 inches over what is currently drawn.

PAHU-2: Basis-of-design make/model shall include a single controls module with the VFD factory mounted and wired. Unit controller shall be furnished loose by manufacturer for field mounting and wiring by the Contractor. Controller shall be mounted inside controls module if space permits; otherwise it shall be mounted on the exterior of the unit in a weathertight controls enclosure. The net effect of deleting the preheat coil and adding the controls module is an increase in the length of the unit of approximately 30 inches over what is currently drawn.

Contractor shall be responsible for field verifying all dimensions and providing a curb adapter.

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____

Fax No.: _____