

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids
Safe Routes to Schools Pedestrian Improvements
15-952**

Date: 12/5/2014
From: Lisa Moss, Buyer VCA
RE: Addendum No. 1

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

- 1. DBE requirement for this project is 0%, however we encourage the use of DBE's and will document same if they are utilized on this project.**

2. Are there any concrete details-reinforcement?
No

- 3. Revised VDOT Entrance drawing attached.**

4. Sheet PM1: is the existing curb ramp to be replaced by the city or contractor?
City

5. New stop bar. What type is it?
Thermo plastic

Company Name: _____ Address: _____ Date: _____

Authorized Signature: _____ Title: _____

Print Name: _____ Telephone No.: _____


Fax No.: _____

TYPE I
Crusher Run Aggr.




6" Crusher Run
Aggr. 25 or 26

TYPE II
Concrete



Concrete Entrance Pavement
7" HES
4" Aggr. Base Mat'l. Ty. I
No. 21B

TYPE III
Asphalt



Asphalt Conc. Type
SM-9.5D @ 220 Lbs. per S. Y.
4" Aggr. Base Mat'l. Ty. I
No. 21B

NOT TO SCALE

TYPE IV
Asphalt Commercial



Asphalt Conc. Type
SM-9.5D @ 165 Lbs. per S. Y.
4" Asphalt Conc. Base Course
BM-25.0A
6" Aggr. Base Mat'l. Ty. I
No. 21B

The type of entrance (I, II, III, IV) to be constructed will be determined by the existing condition at the time of construction.