

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

**Addendum for Invitation for Bids
Wingate Water Storage Tank #2**

14-888

Date: 1/28/2014
From: Lisa Moss, Buyer VCA
RE: Addendum No. 2

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the Contract Documents. The Bidder shall indicate receipt of this Addendum and all previously issued Addenda on the Bid Form.

1. **REVISION TO SPECIFICATION 034800-2.2.J: Currently Requires a bolted 30" diameter manway. REVISION: A 24" x 18" galvanized elliptical type manway is acceptable.**
2. **Note 1 on Drawing C-101 states that "modifications to access road shall be limited to tree trimming." If the contractor requires additional modifications to the access road, they shall be limited to the minimum disturbance required and in no case shall extend ten (10) feet beyond the edge of the existing access road. Contractor shall be responsible for restoring site to original contours and permanently seeding/stabilizing all disturbances. All modifications shall be done in accordance with City of Lynchburg Manual of Specifications and Standard Details and in compliance with Virginia Erosion and Sediment Control Regulations. All modifications shall be approved by the Engineer.**
3. **Specification 034800-2.2-D-10 refers to "prestressed membrane slabs". This refers to a post-tensioned prestressed membrane slab designed in accordance with ACI 318 and Post Tensioning Institute Standards and Specification 034800.**
4. **The bottom of the tank foundation shall be 1285.85 ft MSL or deeper to provide freeze/frost protection.**
5. **The crane height for tank installation shall be limited to a maximum elevation of 1388 ft MSL.**

Company Name: _____ *Address:* _____ *Date:* _____

Authorized Signature: _____ *Title:* _____

Print Name: _____ *Telephone No.:* _____

Fax No.: _____