

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

Addendum for Bid
2013 Municipal Construction Contract
13-835

Date: March 12, 2013

From: Stephanie Suter, CPPO, CPPB

RE: Addendum No. 3

This addendum is supplemental to the project manual, and all changes, deletions and additions shall be part of the Contract as if originally shown in the drawings and specifications. This addendum shall be completed and submitted with all bids.

1. In contradiction to the return response on Addendum No. 2, Item 9, the 2012 Manual states 1,200 feet not 2,000 feet.

The 2,000 foot requirement was in error. All water line bacteriological/pressure testing intervals shall not exceed 1,200 LF in accordance with VDH and AWWA C-651 regulations and standards.

READ TERMS AND CONDITIONS AND SIGN

In compliance with the above BID, and subject to all the conditions hereof, the undersigned offers and agrees to comply with any or all of the terms and conditions contained herein, or as mutually agreed upon by subsequent negotiations. This form shall become part of the final file.

Company Name: _____ *Address:* _____ *Date:* _____

Authorized Signature: _____ *Title:* _____

Print Name: _____ *Telephone No.:* _____ *Fax No.:* _____