







THE CITY OF LYNCHBURG
 STEEL ENCASEMENT DETAIL
 SCALE: NOT TO SCALE
 SHEET: 27.23
 DATE: 12-12-2014

PIPE SIZE (DIA.)	MIN. WALL THICKNESS (IN.)	MIN. COVER (IN.)	MIN. BURIED LENGTH (IN.)	MIN. BURIED LENGTH (FT.)
12"	1/2"	12"	12"	1"
14"	1/2"	12"	12"	1"
16"	1/2"	12"	12"	1"
18"	1/2"	12"	12"	1"
20"	1/2"	12"	12"	1"
24"	1/2"	12"	12"	1"
30"	1/2"	12"	12"	1"
36"	1/2"	12"	12"	1"
42"	1/2"	12"	12"	1"
48"	1/2"	12"	12"	1"
54"	1/2"	12"	12"	1"
60"	1/2"	12"	12"	1"
66"	1/2"	12"	12"	1"
72"	1/2"	12"	12"	1"
78"	1/2"	12"	12"	1"
84"	1/2"	12"	12"	1"
90"	1/2"	12"	12"	1"
96"	1/2"	12"	12"	1"
102"	1/2"	12"	12"	1"
108"	1/2"	12"	12"	1"
114"	1/2"	12"	12"	1"
120"	1/2"	12"	12"	1"



CITY OF LYNCHBURG
 CSO #66 IMPROVEMENTS
 CITY PROJECT #15008-S
 LYNCHBURG, VIRGINIA

COMM NO:	214264.00
DATE:	11/25/2015
DRAWN:	CTS
DESIGN:	ETH
CHECK:	ETH
SHEET TITLE:	DETAILS
SHT. NO.:	C-301
REV. NO.:	0

