

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, Virginia 24504
Telephone No.: (434) 455-3970
Fax No.: (434) 845-0711

Addendum for Bid
GLTC Operations & Maintenance Facility
15-961

Date: February 26, 2015
From: Stephanie Suter, CPPO, CPPB
RE: Addendum No. 3

This Addendum and all attachments become part of the bidding documents and modify the Project Manual and Drawing as noted. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

1. Changes to the bid documents, responses to questions received, and additional clarifications by the design architect/engineer are attached.

READ TERMS AND CONDITIONS AND SIGN

In compliance with the above BID, and subject to all the conditions hereof, the undersigned offers and agrees to comply with any or all of the terms and conditions contained herein, or as mutually agreed upon by subsequent negotiations. This form shall become part of the final file.

Company Name: _____ *Address:* _____ *Date:* _____

Authorized Signature: _____ *Title:* _____

Print Name: _____ *Telephone No.:* _____ *Fax No.:* _____



Project GLTC O&M Facility
Lynchburg, VA
Wendel Project No. 444505

Addendum No. 3
Contract _____
Date 2/26/15

ARTICLE - 3

DRAWING NO. Q301

Vacuum Hose Reel

SPEC
SECTION _____

ADD: Equipment ID #3305- Vacuum Hose reel- CF/CI- 115110- Provide with 1.5"-33 ft long hose, spring retraction- Nederman model # series881EX, part no 30805881. Hose to be Corrugated ethyl vinyl acetate. Provide with wall bracket for mounting within service lane. Total Qty-1.

ARTICLE - 4

DRAWING NO. _____

Metal Building – Mesco Building Solutions

SPEC
SECTION 1078100

SUBSTITUTION: Vendor may be qualified and/or considered an equal to provide the pre-engineered metal building shown and specified, pending review per submittal procedures contained in the specifications during construction.

ARTICLE - 5

DRAWING NO. _____

Addendum No. 2 – ARTICLE 8

SPEC
SECTION _____

REVISE: Article to read “Performance requirements for the windows are in 085113, so that section should be retained for all window types listed in that section. 084113 should be retained for storefront assemblies. Most stringent requirements of either section would apply to windows where an apparent conflict appears.”

OMIT: Omit sentence reading “DELETE: Curtain walls are not required on this project. Delete line A,3 Curtainwall construction in Section 084113 Aluminum-Framed Entrances and Storefronts, Part 1 - General, 1.1 Summary. Delete line A,1,c. Glazed curtainwalls in Section 088000 Glazing, Part 1-General,1.2 Summary.”