

City of Lynchburg  
Procurement Division  
900 Church Street  
Lynchburg, Virginia 24504  
Telephone No.: (434) 455-3970  
Fax No.: (434) 845-0711

**Addendum for Bid**  
**Kanawha Canal Bridge Repairs**  
**2016-066**

---

Date: April 29, 2016

From: Stephanie Suter, CPPO, CPPB

RE: Addendum No. 2

---

This Addendum becomes a part of the bidding documents and modifies the Project Manual and Drawing as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

1. On plan sheet C2 it says to “place geotextile fabric under fill”. What type of geotextile can we use?

Geotextile fabric shall be a woven geotextile, Mirafi HP270 or equal.

**READ TERMS AND CONDITIONS AND SIGN**

In compliance with the above BID, and subject to all the conditions hereof, the undersigned offers and agrees to comply with any or all of the terms and conditions contained herein, or as mutually agreed upon by subsequent negotiations. This form shall become part of the final file.

*Company Name:* \_\_\_\_\_ *Address:* \_\_\_\_\_ *Date:* \_\_\_\_\_

*Authorized Signature:* \_\_\_\_\_ *Title:* \_\_\_\_\_

*Print Name:* \_\_\_\_\_ *Telephone No.:* \_\_\_\_\_ *Fax No.:* \_\_\_\_\_