

TYPE "F" HORIZONTAL ANCHOR BLOCK DATUM					
TYPE FITTING	PIPE SIZE INCHES	DIMENSIONS (Ft.)			VOL. CONC. CU. YARDS
		"L"	"H"	"T"	
TEST PRESSURE = 150 P.S.I. & BELOW					
11 1/4"	16	3	2	3	0.48
22 1/2"	16	4	3	3	0.93
45°	16	6	4	3	1.81
90°	16	8	5.5	3.75	3.92
TEE	16	8	5.5	2.67	3.02
PLUG	16	8	5.5	2.67	3.02
11 1/4"	24	4.5	3	4	1.31
22 1/2"	24	6	4.5	4	2.56
45°	24	8.5	6.25	4	4.97
90°	24	12	8	4.5	9.84
TEE	24	12	8	4	8.94
PLUG	24	12	8	4	8.94
TEST PRESSURE = 151 P.S.I. to 200 P.S.I.					
11 1/4"	16	3	2.67	3	0.63
22 1/2"	16	4.5	3.5	3	1.20
45°	16	7.5	4.25	3	2.40
90°	16	10	5.75	3.75	5.11
TEE	16	10	5.75	5	6.46
PLUG	16	10	5.75	5	6.46
11 1/4"	24	5	3.5	4	1.68
22 1/2"	24	7	5	4	3.30
45°	24	10	7	4	6.54
90°	24	13	10	4.5	13.31
TEE	24	13	10	4.5	13.31
PLUG	24	13	10	4.5	13.31
TEST PRESSURE = 201 P.S.I. to 250 P.S.I.					
11 1/4"	16	3.5	3	3	0.81
22 1/2"	16	5.5	3.67	3	1.53
45°	16	7.5	5.25	3	2.95
90°	16	12	6	3.75	6.38
TEE	16	12	6	4	6.72
PLUG	16	12	6	4	6.72
11 1/4"	24	6	3.75	4	2.14
22 1/2"	24	8	5.5	4	4.13
45°	24	12	7.25	4	8.11
90°	24	14	11.5	4.75	17.21
TEE	24	14	11.5	4.75	17.21
PLUG	24	14	11.5	4.75	17.21



## THE CITY OF LYNCHBURG

### TYPE "F" HORIZONTAL ANCHOR BLOCKING

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

SCALE:  
NOT TO SCALE

DETAIL #  
**26.02**

REVISION DATE:  
12-15-2016

SHEET #:  
**3 OF 3**