



SEE DETAIL 26.23

PRECAST CONCRETE TOP



(2) BRASS STREET ELLS W/THREADED BRASS INSECT SCREEN

ALL JOINTS TO BE T&G W/ PREFORMED BUTYL RUBBER (MASTIC) OR RUBBER GASKET.

BRASS NIPPLE

AIR & VACUUM RELEASE VALVE (AUTOMATIC) 1" OR 2" AS NOTED ON PLANS

CORPORATION STOP

TAPPING SADDLE (SEE DETAIL 26.14)

PRECAST CONCRETE MANHOLE DOGHOUSE BASE

PRECAST CONCRETE BASE OR POURED CONCRETE FOOTING.

GROUT ANNULAR OPENING

STONE TO BOTTOM OF PIPE

VDOT No. 57 STONE

WATER

LINE

18"

6" 10"

VARIES

NOTE:

- 1. CONE SECTION MAY BE SUBSTITUTED FOR FLAT TOP ACCORDING TO DEPTH.



THE CITY OF LYNCHBURG

**AIR & VACUUM RELEASE VALVE
in PRECAST MANHOLE**

SCALE:
NOT TO SCALE

DETAIL #
26.11

REVISION DATE:
12-15-2016

SHEET #:
1 OF 1

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

5/01/2017 - 12:06:26pm