

**NOTES:**

- 29. NO BYPASS IS ALLOWED AROUND ANY RPDA OR RPZ ASSEMBLY. NO TAKEOFFS OR CROSS CONNECTIONS ARE ALLOWED IN FRONT OF ANY RPDA OR RPZ TO INCLUDE, BUT NOT BE LIMITED TO: PRESSURE REDUCING VALVES, ISOLATION OR EXTRA SHUT OFF VALVES, "BLOW DOWNS", DRAIN PORTS, HOSES, EXTRA PIPING. IF A PRESSURE REDUCING VALVE IS NEEDED, ITS USE SHALL BE REVIEWED IN ADVANCE WITH THE COMPLIANCE SPECIALIST.
- 30. ONLY PROPERLY SUPPORTED OUTDOOR GFIC ELECTRICAL RECEPTACLES SHALL BE USED IN THE ENCLOSURE SPECIFIED. ALL RECEPTACLES SHALL BE INSTALLED IN ACCORDANCE WITH ALL APPLICABLE LAWS, ORDINANCES, AND REGULATIONS. RECEPTACLES SHALL NOT BE PLACED DIRECTLY BELOW THE RPZ. ELECTRICAL WORK SHALL BE INSPECTED BY THE CITY BUILDING OFFICIAL.



**THE CITY OF LYNCHBURG**

COMPOUND METER VAULT W/SEPARATE FIRE LINE WITH RPDA AND IRRIGATION SERVICE

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

SCALE:  
**NOT TO SCALE**

DETAIL #  
**26.21**

REVISION DATE:  
**12-15-2016**

SHEET #:  
**5 OF 5**

2/24/2017 - 9:44:04am