

City of Lynchburg
Procurement Division
900 Church Street
Lynchburg, VA 24504
Phone: (434) 455-3970
Fax: (434) 845-0711

**Addendum for Bid
Fire Alarm Services
2019-051**

Date: 05/3/2019

From: Matt Marsteller, Contract Specialist

RE: Addendum No. 1

This Addendum supplements and amends the original Invitation for Bid and shall be taken into account in preparing the bid and shall become a part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

Notes / Clarification from the Optional Pre-Bid on 4-23-19:

1. The City desires to have all pull stations tested and inspected **ANNUALLY** in accordance with the Statewide Fire Prevention Code and NFPA Standards. (not semi-annually as stated in the bid)
2. The City desires to have sensitivity testing performed on 100% of all smoke detectors **BIENNIALY (every two years)** in accordance with the Statewide Fire Prevention Code and NFPA Standards. (not semi-annually as stated in the bid) Due to this change in the frequency of sensitivity testing, a new Bid Form Attachment B has been attached to this Addendum with a revision date of **5-3-19**. A new row has been added under each location requesting the cost for Biennial sensitivity testing. **PLEASE ENSURE THE NEW BID FORM IS USED.**
3. **Question: Who is currently providing Fire Alarm services?**
Answer: VSC Fire and Security Inc.
4. **Question: What Central Monitoring Station provides monitoring services?**
Answer: The City of Lynchburg does not have a central monitoring station. Current monitoring service is provided by VSC Fire and Security Inc.
5. **Question: Can one semi-annual inspection be combined with annual inspection and be done at the same time?**
Answer: Yes

6. **Question: Is elevator testing part of this scope of work? If so will elevator subcontractor be provided or this is a responsibility of the FA Contractor?**

Answer: Elevator testing is not part of this scope of work. We have a separate contract for Elevator testing.

7. **Question: Does any of the locations require lift? If so if there is lift on-site that could be used or this will be responsibility of the Contractor?**

Answer: To the knowledge of City Staff, none of the locations would require a lift. None of the Staff for our current service provider have ever requested a lift or brought the need to have a lift to the attention of City Staff.

8. **Question: Does any of the locations need to be tested afterhours or on weekends?**

Answer: No, none of the locations need to be tested after hours or on weekends. City Court buildings will need to be scheduled for logistical reasons; however, services can be performed during business hours.

9. A request was made for the City to make the Fire Panel Dialer Information available. (FireLite, Silent Night, Simplex, etc.) A revised Fire Alarm Equipment List Attachment A with a revision date of **5-3-19** is attached to this Addendum. A column has been added for the Fire Panel Dialer Information. Those locations where monitoring service is being requested by the City have the panel dialer information noted. Those locations where monitoring service is not being requested by the City are noted as N/A. Also, Fire Stations 3 & 6 have been added to the Fire Alarm Equipment List Attachment A.

10. The new Bid Form also reflects the removal of the City's initial request for alarm monitoring services at various locations throughout the City. The new Bid Form also adds Fire Stations 3 & 6 to the list of locations for which the City is requesting services.

READ TERMS AND CONDITIONS AND SIGN

In compliance with the above BID, and subject to all the conditions hereof, the undersigned offers and agrees to comply with any or all of the terms and conditions contained herein, or as mutually agreed upon by subsequent negotiations. This form shall become part of the final file.

Company Name: _____ *Address:* _____ *Date:* _____

Authorized Signature: _____ *Title:* _____

Print Name: _____ *Telephone No.:* _____ *E-mail:* _____

Fire Alarm Equipment List Attachment A (Revised 5-3-19)

LOCATION/DEVICE	ADDRESS	QUANTITY	EQUIPMENT	FIRE PANEL DIALER INFORMATION
FIRE STATION #3	4701 FORT AVE LYNCHBURG, VA 24502	1	FIRELITE 9050UD	FIRELITE 9050UD
		8	Smoke Detector (Photo)	
		3	Pull Station	
		4	Horn/Strobe	
FIRE STATION #6	2084 FORT AVE LYNCHBURG, VA 24502	1	FIRELITE MS-9050UDLS	FIRELITE MS9050UD
		26	Smoke Detector (Photo)	
		5	Pull Station	
		10	Horn/Strobe	
FIRE ADMINISTRATION	800 MADISON STREET LYNCHBURG, VA 24504	1	Simplex 4010	SILENT NIGHT 5128
		10	Smoke Detector (Photo)	
		4	Pull Station	
		4	Horn/Strobe	
HEALTH DEPARTMENT	307 ALLEGHENY AVE 801 LAKESIDE DR LYNCHBURG, VA 24501	1	Siemens FHD 2002-U3	FS-250
		4	Smoke Detector (Photo)	
		18	Duct Detector	
		6	Pull Station	
		33	Horn/Strobe	
		32	Strobe Only	
CIRCUIT COURT BUILDING	900 COURT STREET LYNCHBURG, VA 24504	1	Siemens MKB-4	SILENT NIGHT 5128
		15	Smoke Detector (Photo)	
		5	Smoke Detector (ion)	
		1	Duct Detector	
		5	Pull Station	
		1	Flow Switch	
		3	Heat Detector (Fixed)	
		3	Horn/Strobe	
		2	Tamper	
MILLER CENTER	301 GROVE STREET LYNCHBURG, VA 24501	1	Siemens FHD2002-U3	CERBERUS PRO
		19	Smoke Detector (Photo)	
		13	Pull Station	
		3	Tampers	
		21	Horn/Strobe	
		6	Strobe Only	
CITY CEMETERY CHAPEL	401 TAYLOR STREET LYNCHBURG, VA 24501	1	MAXSYS DSC PC4020CF	MAXSYS DSC 4020
		5	Smoke Detector (Photo)	
		4	Door Contacts	
		9	Window Contacts	
CEMETERY, PEST & HEARSE HOUSE	401 TAYLOR STREET LYNCHBURG, VA 24501	1	ADEMCO VISTA50P	VISTA50P ADEMCO
		13	Smoke Detector (Photo)	
		1	Duct Detector	
		7	Motion Detector	
		2	Door Contact	
HUMAN SERVICES	99 9TH STREET LYNCHBURG, VA 25404	1	Notifier AM2020 / AFP 1010	SILENT NIGHT 5129
		25	Smoke Detector (Photo)	
		9	Duct Detector	
		17	Pull Station	
		6	Heat Detector (ROR)	
		52	Horn/Strobe	
		42	Strobe Only	
LIBRARY GROUP BUILDING	2311 MEMORIAL AVE. LYNCHBURG, VA 24501	1	Simplex 4010	SILENT KNIGHT 5129
		3	Smoke Detector (Photo)	
		5	Duct Detector	
		8	Pull Station	
		10	Horn/Strobe	

Fire Alarm Equipment List Attachment A (Revised 5-3-19)

LOCATION/DEVICE	ADDRESS	QUANTITY	EQUIPMENT	FIRE PANEL DIALER INFORMATION
CITY HALL	900 CHURCH STREET LYNCHBURG, VA 24504	1	Simplex 4010	SK-5128
		81	Smoke Detector (Photo)	
		2	Duct Detector	
		14	Pull Station	
		1	Heat Detector (ROR)	
		19	Horn/Strobe	
MONUMENT TERRACE	901 CHURCH STREET LYNCHBURG, VA 24504	1	Kidde FX 1000D	Kidde FX 1000D
		15	Smoke Detector (Photo)	
		8	Pull Station	
		5	Heat Detector (ROR)	
		13	Horn/Strobe	
		2	Strobe Only	
INFORMATION TECHNOLOGY	2550 YOUNG PLACE LYNCHBURG, VA 24501	1	Siemens FS-250	N/A
		5	Smoke Detector (Photo)	
		10	Pull Station	
		21	Horn/Strobe	
		7	Strobe Only	
COMMUNITY MARKET	1219 MAIN STREET LYNCHBURG, VA 24504	1	Edwards E-FSA	SILENT KNIGHT 5129
		11	Smoke Detector (Photo)	
		3	Duct Detector	
		16	Pull Station	
		2	Heat Detector (ROR)	
		8	Horn/Strobe	
		2	Strobe Only	
J&D COURT	909 COURT STREET LYNCHBURG, VA 24504	1	Simplex 4100	SK-5128
		29	Smoke Detector (Photo)	
		7	Duct Detector	
		27	Pull Station	
		6	Heat Detector (ROR)	
		43	Horn/Strobe	
		45	Strobe Only	
BASEBALL STADIUM	3180 FORT AVENUE LYNCHBURG, VA 24501	1	Notifier AFP-200	SILENT KNIGHT 5128
		7	Smoke Detector (Photo)	
		3	Duct Detector	
		16	Pull Station	
		3	Heat Detector (ROR)	
		14	Horn/Strobe	
		1	Horn Only	
		6	Strobe Only	
FOOTBALL STADIUM	3180 FORT AVENUE LYNCHBURG, VA 24501	1	NOTIFIER	NOTIFIER
		2	Smoke Detector (Photo)	
		1	Pull Station	
		13	Horn/Strobe	
		3	Strobe Only	
KEMPER STREET STATION VOTERS REGISTRARS OFFICE	825 KEMPER STREET LYNCHBURG, VA 24501	1	Notifier AFP-200	N/A
		46	Smoke Detector (Photo)	
		5	Duct Detector	
		14	Pull Station	
		3	Heat Detector (ROR)	
		14	Horn/Strobe	
		8	Strobe Only	
B&G MAINTENANCE	800 ORCHARD STREET LYNCHBURG, VA 24501	1	Simplex 4005	GSM/I
		1	Duct Detector	
		2	Alarm Bell	
		2	Horn Only	

Fire Alarm Equipment List Attachment A (Revised 5-3-19)

LOCATION/DEVICE	ADDRESS	QUANTITY	EQUIPMENT	FIRE PANEL DIALER INFORMATION
YOUTH GROUP HOME	1404 FLORIDA AVE LYNCHBURG, VA 24501	1	SIMPLEX 4010 ES	SIMPLEX
		5	Smoke Detector (Photo)	
		7	Duct Detector	
		6	Pull Station	
		12	Multi-Criteria Detector	
		18	Horn/Strobe	
		50	Strobe Only	
OPPORTUNITY HOUSE 2	1517 JACKSON STREET LYNCHBURG, VA 24502	1	Pyronics System 3	N/A
		33	Smoke Detector (Photo)	
		10	Pull Station	
		8	Heat Detector (fixed)	
		6	Horn Only	
FLEET SERVICES	1700 MEMORIAL AVENUE LYNCHBURG, 24501	1	Notifier AFP-200	N/A
		3	Smoke Detector (Photo)	
		2	Duct Detector	
		12	Pull Station	
		20	Horn/Strobe	
JUVENILE DETENTION	1400 FLORDIA AVENUE LYNCHBURG, 24501	1	Siemens MXL-IQ	N/A
		61	Smoke Detector (Photo)	
		7	Duct Detector	
		20	Pull Station	
		7	Heat Detector (ROR)	
		12	Horn/Strobe	
		7	Strobe Only	
COURTHOUSE MUSEUM	901 COURT STREET LYNCHBURG, VA 24504	1	Siemens MXL	N/A
		53	Smoke Detector (Photo)	
		11	Duct Detector	
		7	Pull Station	
		1	Heat Detector (ROR)	
		12	Horn/Strobe	
		5	Strobe Only	
WASTE WATER MAINTENANCE	2301 CONCORD TURNPIKE LYNCHBURG, VA 24502	1	Simplex 4010	SILENT KNIGHT 5128
		9	Smoke Detector (Photo)	
		9	Pull Station	
		3	Heat Detector (ROR)	
		1	Heat Detector (fixed)	
		9	Horn/Strobe	
		2	Strobe Only	
WASTE WATER CONTROL BUILDING	2301 CONCORD TURNPIKE LYNCHBURG, VA 24504	1	Bosch	N/A
		10	Pull Station	
		10	Horn/Strobe	
WASTE WATER DEWATERING	2301 Concord Turnpike LYNCHBURG, VA 24503	1	Fire-Lite ES-50X	N/A
		1	Smoke Detector (Photo)	
		1	Elevator Bypass Key	
		2	Duct Detector	
		4	Heat Detector (fixed)	
		1	Horn/Strobe	
WASTE WATER ODOR CONTROL	2301 CONCORD TURNPIKE LYNCHBURG, VA 24504	1	Notifier SFP-1024	N/A
		4	Smoke Detector (Photo)	
		3	Pull Station	
		4	Horn/Strobe	
WATER RESOURCES ADMIN BUILDING	525 TAYLOR STREET LYNCHBURG, VA 24501	1	SIMPLEX 4010	SILENT KNIGHT 5129 - ALL 3
		51	Smoke Detector (Photo)	BUILDINGS ARE TIED TO ONE DIALER
		18	Pull Station	

Fire Alarm Equipment List Attachment A (Revised 5-3-19)

LOCATION/DEVICE	ADDRESS	QUANTITY	EQUIPMENT	FIRE PANEL DIALER INFORMATION
		3	Heat Detector (ROR)	
		29	Horn/Strobe	
		18	Strobe Only	
WATER RESOURCES FILTRATION	525 TAYLOR STREET LYNCHBURG, VA 24503	1	SIMPLEX 4100U	SILENT KNIGHT 5129 - ALL 3
		17	Smoke Detector (Photo)	BUILDINGS ARE TIED TO ONE DIALER
		6	Duct Detector	
		7	Pull Station	
		6	Horn/Strobe	
		10	Strobe Only	
WATER RESOURCES METER SHOP	525 TAYLOR STREET LYNCHBURG, VA 24501	1	Simplex 4010	SILENT KNIGHT 5129 - ALL 3
		21	Smoke Detector (Photo)	BUILDINGS ARE TIED TO ONE DIALER
		1	Duct Detector	
		8	Pull Station	
		10	Heat Detector (ROR)	
		18	Horn/Strobe	
		5	Strobe Only	
LYNCHBURG REGIONAL AIRPORT MAIN TERMINAL	350 TERMINAL DRIVE LYNCHBURG, VA 24502	1	Siemens Firefinder	SILENT KNIGHT 5128
		22	Smoke Detector (Photo)	
		12	Duct Detector	
		16	Pull Station	
		52	Horn/Strobe	
		1	Strobe Only	
LYNCHBURG REGIONAL AIRPORT ARFF	306 TERMINAL DRIVE LYNCHBURG, VA 24502	1	Siemens Firefinder	SILENT KNIGHT 5128
		6	Smoke Detector (Photo)	
		4	Duct Detector	
		4	Pull Station	
		8	Horn/Strobe	
		2	Strobe Only	
LYNCHBURG REGIONAL AIRPORT Maintenance Shop	618 HANGAR ROAD LYNCHBURG, VA 24502	1	Simplex 4004	SILENT KNIGHT 5128
		4	Smoke Detector (Photo)	
		3	Pull Station	
		3	Heat Detector (FIXED)	
		4	Horn/Strobe	
		1	Strobe Only	
		2	Horn Only	
LYNCHBURG REGIONAL AIRPORT New Tower	116 HANGAR ROAD LYNCHBURG, VA 24502	1	SIMPLEX 4100 ES	SIMPLEX
		8	Smoke Detector (Photo)	
		4	Pull Station	
		1	Heat Detector (ROR)	
		5	Horn/Strobe	
		1	Strobe Only	
LYNCHBURG REGIONAL AIRPORT Banker Aviation	982 AIRPORT ROAD LYNCHBURG, VA 24502	1	Fire-Lite MS-905	N/A
		3	Smoke Detector (Photo)	
		3	Pull Station	
		6	Horn/Strobe	
		3	Strobe Only	
LYNCHBURG REGIONAL AIRPORT GENERAL AVIATION	970 AIRPORT ROAD LYNCHBURG, VA 24052	1	EDWARDS FSA-64	EDWARDS FSA-64
		2	Smoke Detector (Photo)	
		4	Duct Detector	
		3	Pull Station	
		5	Horn/Strobe	
Equipment List Revised 5-3-19		8	Strobe Only	

Fire Alarm Services Bid Form

Attachment B

Location	System	Type of Service	Inspection & Billing Intervals	Unit Cost per Inspection	Total Line Item Cost
PLEASE BILL THE FOLLOWING 24 LOCATIONS TO BUILDINGS AND GROUNDS					
Fire Station #3	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Fire Station #6	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Fire Administration	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Health Department	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Circuit Court Building	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Miller Center	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$

Miller Center (cont.)	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
City Cemetary Chapel	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
City Cemetary Pest and Hearse House	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Human Services	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Library Group Building	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
City Hall	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Monument Terrace	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$

Information Technology	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Community Market	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
J&D Court	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Lynchburg City Baseball Stadium	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Lynchburg City Football Stadium	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Kemper St. Station Voters Registration Office	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
B&G Maintenance	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$

Youth Group Home	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Opportunity House 2	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Fleet Services	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Juvenile Detention Center	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Courthouse Museum	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$

PLEASE BILL THE FOLLOWING 4 LOCATIONS TO THE WASTE WATER TREATMENT PLANT

Waste Water Maintenance	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Waste Water Control Building	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$

Waste Water	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Dewatering	Fire Alarm	Test & Inspect	Annually	N/A
Fire Alarm		Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Waste Water	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Odor Control	Fire Alarm	Test & Inspect	Annually	N/A
Fire Alarm		Sensitivity Testing	Every Two Years (Biennially)	N/A	\$

PLEASE BILL THE FOLLOWING 3 LOCATIONS TO THE DEPARTMENT OF WATER RESOURCES

Water Resources	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Admin.	Fire Alarm	Test & Inspect	Annually	N/A
Fire Alarm		Monitor	Annually	N/A	\$
Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$	
Water Resources	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Filtration	Fire Alarm	Test & Inspect	Annually	N/A
Fire Alarm		Monitor	Annually	N/A	\$
Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$	
Water Resources	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Meter Shop	Fire Alarm	Test & Inspect	Annually	N/A
Fire Alarm		Monitor	Annually	N/A	\$
Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$	

PLEASE BILL THE FOLLOWING 6 LOCATIONS TO THE LYNCHBURG REGIONAL AIRPORT

Lynchburg Reg. Airport	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Main Terminal	Fire Alarm	Test & Inspect	Annually	N/A
Fire Alarm		Monitor	Annually	N/A	\$
Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$	
Lynchburg Reg. Airport	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	ARFF	Fire Alarm	Test & Inspect	Annually	N/A

Lynchburg Reg. Airport ARFF (cont.)	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Lynchburg Reg. Airport Maintenance Shop	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Lynchburg Reg. Airport New Tower	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Lynchburg Reg. Airport Banker Aviation	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
Lynchburg Reg. Airport General Aviation	Fire Alarm	Test & Inspect	Semi Annual (x2)	\$	\$
	Fire Alarm	Test & Inspect	Annually	N/A	\$
	Fire Alarm	Monitor	Annually	N/A	\$
	Fire Alarm	Sensitivity Testing	Every Two Years (Biennially)	N/A	\$
BID FORM REVISED ON 5-3-19				Total Base Bid Cost: \$	

Prices quoted shall remain valid for twelve (12) months from date of original bid.

Prices for services shall include all labor and materials needed to complete the Scope of Work.