

NOTES:

- 29. SERVICE CONNECTIONS SHALL NOT BE UTILIZED FOR DEMOLITION, GRADING, CONSTRUCTION/RENOVATION, AND OR LANDSCAPING PURPOSES UNLESS THE APPROPRIATE RP'S* HAVE BEEN INSTALLED AND PASSING TESTS HAVE BEEN SUBMITTED TO DWR. THIS INCLUDES TEMPORARY AND PERMANENT CONNECTIONS.
- 30. NO BYPASS IS ALLOWED AROUND ANY RP* ASSEMBLY. NO TAKEOFFS OR CROSS CONNECTIONS ARE ALLOWED IN FRONT OF ANY RP* TO INCLUDE, BUT NOT BE LIMITED TO: PRESSURE REDUCING VALVES, ISOLATION OR EXTRA SHUT OFF VALVES, "BLOW DOWNS", DRAIN PORTS, HOSES, EXTRA PIPING. IF A PRESSURE REDUCING VALVE IS NEEDED, ITS USE SHALL BE REVIEWED IN ADVANCE WITH THE COMPLIANCE SPECIALIST.
- 31. ONLY PROPERLY SUPPORTED OUTDOOR GFIC ELECTRICAL RECEPTACLES SHALL BE USED IN THE ENCLOSURE SPECIFIED. ALL RECEPTACLES SHALL BE INSTALLED IN ACCORDANCE WITH ALL APPLICABLE LAWS, ORDINANCES, AND REGULATIONS. RECEPTACLES SHALL NOT BE PLACED DIRECTLY BELOW ANY RP*. ELECTRICAL WORK SHALL BE INSPECTED BY THE CITY BUILDING OFFICIAL.

THE CITY OF LYNCHBURG



COMPOUND METER VAULT W/SEPARATE FIRE LINE WITH RP* AND IRRIGATION SERVICE

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

SCALE:
NOT TO SCALE

DETAIL #
26.21

REVISION DATE:
4-2020

SHEET #:
5 OF 5