



NOTES:

1. FOUNDATION STONE SHALL BE REQUIRED WHEN SOIL CONDITIONS ARE UNSUITABLE.
2. EXTRA DEPTH EXCAVATION SHALL BE PAID FOR AS ANYTHING BEYOND 4' OF COVER TO TOP OF PIPE.
3. AN ADDITIONAL 1 INCH DEPTH OF BEDDING STONE WILL BE REQUIRED FOR EACH ADDITIONAL 2 FEET OF TRENCH DEPTH IN EXCESS OF 16 FEET UP TO A MAXIMUM OF 12 INCHES.
4. IF COVER DEPTH IS LESS THAN 4 FEET, DIP SHALL BE REQUIRED UNLESS OTHERWISE DIRECTED BY THE CITY ENGINEER.

5/05/2020 - 11:34:31am



THE CITY OF LYNCHBURG

SANITARY SEWER LINE
TRENCH DETAIL

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

SCALE:
NOT TO SCALE

REVISION DATE:
4-2020

DETAIL #
27.01

SHEET #:
1 OF 1